



Connecting the Terminal Block

Connect main supply (brown - live, blue - neutral) into terminal block making sure all connections are tight.

Please read instructions before commencing installation and retain for future reference.

CAUTIONS :

1. Switch-off the power supply before any installation and maintenance operations.
2. Installation should be carried out by a suitably qualified person in accordance with good electrical practice and the appropriate national wiring regulations.
3. Connect this lighting according to voltage and frequencies mention on driver.

INSTALLATION :

SPECIFICATIONS:

- **Fitting:** Aluminum. GU10 35W MAX (Exclude)
- **Protection against electric shock:** CLASS I.
- **Ingress Protection:** IP20.
- **Quality/Corrosive rating:** QC21: Burning period: 12hrs/24hr cycle. Commercial use, indoor mainly - painted or plated metals. Not for use in corrosive environments.
- **Driver:** Included.
- **Ambient temperature range:** -20°C to +40°C.

